

PRODUCT SPECIFICATION
and
DECLARATION OF CONFORMITY

RIAWATECH hereby issue a declaration of conformity for:
**RIA SPK-TG sluice gate,
for flow control of water and wastewater**

The product is manufactured and marketed by:
RIAWATECH, Aggershusvej 7, 5450 Otterup Denmark
Phone: +45 64 82 40 00

Name: RIA SPK-TG sluice gate

Type: RIA SPK-TG
Dimensions: DN 200 – DN 800
Material: EN 1.4404 (EN 1.4462), HDPE 500

Declaration according to below:
DIN 19569-4-2000-11, Class 4.

Wastewater treatment plants – Principles for the design of structures and technical equipment – Part 4: Specific principles for shutoff devices as penstocks, sluice gates, stoplogs etc.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Date: 27.01.2022

Yours sincerely,



Sandra Edvardsson
Quality Manager
Wapro Group

PRODUCT SPECIFICATION
and
DECLARATION OF CONFORMITY

RIAWATECH hereby issue a declaration of conformity for:
**RIA SPM-P sluice gate,
for flow control of water and wastewater**

The product is manufactured and marketed by:
RIAWATECH, Aggershusvej 7, 5450 Otterup Denmark
Phone: +45 64 82 40 00

Name: RIA SPM-P sluice gate

Type: RIA SPM-P
Dimensions: DN 800x800 – DN 1400x1400, (customized on request)
Material: EN 1.4404 (EN 1.4462), PEHD 500

Declaration according to below:
DIN 19569-4-2000-11, Class 4.

Wastewater treatment plants – Principles for the design of structures and technical equipment – Part 4: Specific principles for shutoff devices as penstocks, sluice gates, stoplogs etc.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Date: 27.01.2022

Yours sincerely,



Sandra Edvardsson
Quality Manager
Wapro Group

PRODUCT SPECIFICATION
and
DECLARATION OF CONFORMITY

RIAWATECH hereby issue a declaration of conformity for:
**RIA SPM-S sluice gate,
for flow control of water and wastewater**

The product is manufactured and marketed by:
RIAWATECH, Aggershusvej 7, 5450 Otterup Denmark
Phone: +45 64 82 40 00

Name: RIA SPM-S sluice gate

Type: RIA SPM-S
Dimensions: DN 800x800 – DN 1400x1400, (customized on request)
Material: EN 1.4404 (EN 1.4462), PEHD 500

Declaration according to below:
DIN 19569-4-2000-11, Class 4.

Wastewater treatment plants – Principles for the design of structures and technical equipment – Part 4: Specific principles for shutoff devices as penstocks, sluice gates, stoplogs etc.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Date: 27.01.2022

Yours sincerely,



Sandra Edvardsson
Quality Manager
Wapro Group